



Inspection Report

Coyote Consulting Company Inc
77 Vine Street
Douglas, MA 01516

Customer ID: **26120**

Certificate: **14-A-0039**

Site: 002

Coyote Consulting Company Inc

Type: ROUTINE INSPECTION

Date: 10-FEB-2026

3.126(b)

Facilities, indoor.

The pigs are housed in multiple pens located in one large room that does not have windows. There was a strong smell of ammonia noted by the inspector upon entering the room and was strongest at both ends of the room. Although the ventilation system fans are set to run for a set time each hour, facility personnel determined that the roof-mounted ventilation fans were not operating properly. As a result, the ventilation system was not providing effective ventilation to minimize the strong ammonia odor in the housing room.

Per this Section, indoor housing facilities shall be adequately ventilated at all times by natural or mechanical means to provide for the health of the animals and to prevent discomfort. Indoor housing facilities shall be provided with fresh air either by means of windows, doors, vents, or fans, and shall be ventilated to minimize odors. The licensee needs to address the ventilation of the swine housing room to minimize strong ammonia odor for the health of the animals. Correct by incorporating measures to temporarily address the ammonia odor in the housing room by 2/17/26 followed by repair/replacement of the roof-mounted ventilation system by 6/12/26.

This inspection and exit briefing were conducted with facility representative.

END OF REPORT

Prepared By: PAULA GLADUE
USDA, APHIS, Animal Care
Title: VETERINARY MEDICAL OFFICER

Date:
13-FEB-2026

Received by Title: Licensee

Date:
13-FEB-2026



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
26120	14-A-0039	002	Coyote Consulting Company Inc	10-FEB-2026

Count	Scientific Name	Common Name
000059	<i>Sus scrofa domestica</i>	DOMESTIC PIG / POTBELLY PIG / MICRO PIG
000059	Total	