



Inspection Report

Coyote Consulting Company Inc
77 Vine Street
Douglas, MA 01516

Customer ID: **26120**

Certificate: **14-B-0044**

Site: 002

Coyote Consulting Company Inc

Type: ROUTINE INSPECTION

Date: 10-MAY-2022

3.126(b)

Facilities, indoor.

The pigs were housed in multiple pens located in one large room. There was a strong smell of ammonia noted by the inspector upon entering the room and the smell of ammonia was stronger in one end of the room. Ventilation system fans were running, but the system was not providing effective ventilation to minimize the strong ammonia odor in the housing room.

Per this Section, indoor housing facilities shall be adequately ventilated at all times by natural or mechanical means to provide for the health of the animals and to prevent discomfort. Indoor housing facilities shall be provided with fresh air either by means of windows, doors, vents, fans, or air-conditioning and shall be ventilated to minimize drafts, odors, and moisture condensation. The licensee needs to address the strong ammonia odor and improve the ventilation of the swine housing room to minimize odors and for the health of the animals. Correct by 5/27/22.

This inspection and exit briefing were conducted 5/10/22 with facility representatives.

Prepared By: PAULA GLADUE

USDA, APHIS, Animal Care

Date:
13-MAY-2022

Title: VETERINARY MEDICAL
OFFICER

Received by Title: Licensee

Date:
13-MAY-2022



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
26120	14-B-0044	002	Coyote Consulting Company Inc	10-MAY-2022

Count	Scientific Name	Common Name
000018	<i>Sus scrofa domestica</i>	DOMESTIC PIG / POTBELLY PIG / MICRO PIG
000018	Total	