



Inspection Report

Phillip M Moberley
1117 S Crestline St
Spokane, WA 99202

Customer ID: **45079**

Certificate: **33-B-0422**

Site: 001

PHILLIP MOBERLEY

Type: ROUTINE INSPECTION

Date: 27-FEB-2014

3.26(d) REPEAT

FACILITIES, INDOOR.

***** The ceiling panels in the animal facility are not adequately affixed to the ceiling. The panels are bowed, leaving gaps at the seams of the panels. There is a large opening around one of the vents in the ceiling . The surfaces can not be readily cleaned and sanitized as required. The gap openings can provide access areas for the harborage of insects, rodents, and/or other pests. The ceiling and wall panels are not in a good state of repair. Repair and/or replace wall and ceiling panels to facilitate the prescribed husbandry practices and to promote the health and well-being of the animals housed in the facility.

INSPECTION AND EXIT BRIEFING CONDUCTED WITH THE FACILITY REPRESENTATIVE.

Prepared By: DAWN BARKSDALE, D V M USDA, APHIS, Animal Care

Date:
06-MAR-2014

Title: VETERINARY MEDICAL OFFICER 1062

Received by Title: SENT BY CERTIFIED MAIL

Date:
06-MAR-2014



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
45079	33-B-0422	001	PHILLIP MOBERLEY	27-FEB-14

Count	Scientific Name	Common Name
000055	<i>Acomys wilsoni</i>	WILSON'S SPINY MOUSE
000183	<i>Atelerix albiventris</i>	HEDGEHOG
000011	<i>Cavia porcellus</i>	DOMESTIC GUINEA PIG
000001	<i>Chinchilla lanigera</i>	CHINCHILLA
000047	<i>Monodelphis domestica</i>	GREY SHORT-TAILED OPOSSUM
000034	<i>Octodon degus</i>	DEGU
000042	<i>Petaurus breviceps</i>	SUGAR GLIDER
000004	<i>Spermophilus richardsonii</i>	RICHARDSON'S GROUND SQUIRREL
000377	Total	